

Issued To:
 Wercore Cleaning & Pest Control Services LLC
 Dubai

Report No : R1-240321-98
 Report Date : 25/03/2024
 Request No : Q1-240321-38

TEST REPORT

Sample Number	: S1-240321-98	Receiving Date	: 21/03/2024
Sample Description	: Domestic Water	Sampling Date/Time	: 21/03/2024; 03:40 PM
Customer Sample ID	: N/A	Sample Temperature	: 34.2°C
Project Name	: Woodlem Park school	Sample Volume Collected	: 500mL
Source of Sample	: Woodlem Park school, Street No.10, Al Qusais School Zone, Near Lulu hyper Market	Sampling Point	: Ground RCC Tank
Sampled By	: EMP ID U13(T11)	Sample Receipt Temperature	: 32.4°C
Sampling Procedure	: APHA 9060	Neutralizer Used	: Sodium thiosulfate
Sampling Apparatus	: Sterile Plastic Bottle	On site Observation	: Clear
Sample Container	: Sterile Plastic Bottle	Mode of Transportation	: Cool Box
Pre-Flush/Post-Flush	: N/A	Client Reference (if any)	: N/A

Test Results - Microbiology

Date of Analysis: 21/03/2024 - 23/03/2024

S. No.	Test Parameters	Method	Unit	UoM (%)	Results	Specification
1	Total Bacterial Count	APHA 9215B	CFU/ml	6.4	<1	500 CFU/ml

Statement of conformity: The results of above sample are in comply with specification limit.

Specification Reference: DM-HSD-GU44-LCWS2 Technical Guidelines for Legionella Control in Water system.

Tested By: EMP ID: 006,016

Note: a The GSO 149/2021 doesn't specify the limit for Aerobic Colony Count, So the specification limit was taken from DM-HSD-GU44-LCWS2 Technical Guidelines for Legionella Control in water system.

* The information's supplied by the customer can affect the validity of results

Test Method Variation: None

Signed for and on behalf of Testhub Laboratories LLC




 Laboratory Manager

Form No: TH-01-01-01-002 Issue No: 2 Issued On: 11-09-2023

This report shall not be reproduced, unless in its entirety, without written approval from Testhub Laboratories LLC. The results state only to the material or product analyzed. Keywords: NI = Not Detected, NA = Not Analyzed, ppm - Parts per million, ppb - Parts per billion, LOQ - Limit of Quantification, LOD = Limit of Detection, CFU = Colony Forming Unit, UoM=Measurement Uncertainty. Applied Decision Rule: For qualitative measurements and for zero value specifications, simple acceptance rule shall be followed by considering uncertainty U=0. For other type of specification values, binary acceptance based on guard banding formula shall be followed $U=0.5 \times U$.

End of Report

Page 1 of 1

Issued To:
 Wercore Cleaning & Pest Control Services LLC
 Dubai

Report No : RI-240321-99
 Report Date : 01/04/2024
 Request No : Q1-240321-38

TEST REPORT

Sample Number	: S1-240321-99	Receiving Date	: 21/03/2024
Sample Description	: Domestic Water	Sampling Date/Time	: 21/03/2024; 03:40 PM
Customer Sample ID	: N/A	Sample Temperature	: 34.2°C
Project Name	: Woodlem Park school	Sample Volume Collected	: 1000mL
Source of Sample	: Woodlem Park school, Street No.10, Al Qusais School Zone, Near Lulu hyper Market	Sampling Point	: Ground RCC Tank
Sampled By	: EMP ID 013(TH)	Sample Receipt Temperature	: 32.4°C
Sampling Procedure	: BS 7592	Neutralizer Used	: Sodium thiosulfate
Sampling Apparatus	: Sterile Plastic Bottle	On site Observation	: Clear
Sample Container	: Sterile Plastic Bottle	Mode of Transportation	: Cool Box
Pre-Flush/Post-Flush	: N/A	Client Reference (if any)	: N/A

Test Results - Legionella

Date of Analysis: 21/03/2024- 31/03/2024

S. No.	Test Parameters	Method	Unit	UoM (%)	Results	Specification
1	Legionella sp.,	ISO 11731: 2017	CFU/L	10.9	Not Detected	<1000

Note: Confirmatory Test for Legionella sp.,
 Legionella species - Absent
 Legionella pneumophila serotype 1 - Absent
 Legionella pneumophila serotype 2-14 - Absent

Statement of conformity: The results of above sample are in comply with specification limit.

Specification Reference: DM-HSD-GU44-LCWS2 Technical Guidelines for Legionella Control in Water system.

Test Procedure: 7 Media Used: GVPC

Sample Volume Filtered: 250mL and Detection limit - 4 CFU/L

Tested By: EMP ID: 006,008

Note: * The informations supplied by the customer can affect the validity of results.

Test Method Variation: None



Signed for and on behalf of Testhub Laboratories LLC


 Manu P
 Laboratory Manager

This report shall not be reproduced, unless in its entirety, without written approval from Testhub Laboratories. The results relate only to the material or product analyzed. Keywords: ND = Not Detected, NA = Not Analyzed, ppm = Parts per million, ppb = Parts per billion, LQ = Limit of Quantification, LOD = Limit of Detection, CFU = Colony Forming Unit, UoM = Measurement Uncertainty. Applied Decision Rule: For qualitative measurements and for zero value specifications, simple acceptance rule shall be followed by considering uncertainty U=0. For other type of specification values, Heary acceptance based on guard banding formula shall be followed $U=0.5 \times U_{\text{max}}$.

Issued To:
 Wercore Cleaning & Pest Control Services LLC
 Dubai

Report No : R1-240415-122
 Report Date : 18/04/2024
 Request No : Q1-240415-40

TEST REPORT

Sample Number	: 51-240415-122	Receiving Date	: 15/04/2024
Sample Description	: Domestic Water	Sampling Date/Time	: 15/04/2024; 03:45 PM
Customer Sample ID	: N/A	Sample Temperature	: 32.6°C
Project Name	: Woodlem Park school	Sample Volume Collected	: 500mL
Source of Sample	: Woodlem Park school, Street No.10, Al Qusais School Zone, Near Lulu hyper Market	Sampling Point	: Ground Boys Washroom
Sampled By	: EMP ID 013(TH)	Sample Receipt Temperature	: 30.1°C
Sampling Procedure	: APHA 9060	Neutralizer Used	: Sodium thiosulfate
Sampling Apparatus	: Sterile Plastic Bottle	On site Observation	: Clear
Sample Container	: Sterile Plastic Bottle	Mode of Transportation	: Cool Box
Pre-Flush/Post-Flush	: Post-Flush	Client Reference (if any)	: N/A

Test Results - Microbiology

Date of Analysis : 15/04/2024- 17/04/2024

S. No.	Test Parameters	Method	Unit	UoM (%)	Results	Specification
1	Total Bacterial Count	APHA 9215B	CFU/ml	6.4	<1	500 CFU/ml*

Statement of conformity: The results of above sample are in comply with specification limit.

Specification Reference: DM-HSD-GU44-LCWS2 Technical Guidelines for Legionella Control in Water system.

Tested By: EMP ID: 006,016

Note: a The GSO 149/2021 doesn't specify the limit for Aerobic Colony Count, So the specification limit was taken from DM-HSD-GU44-LCWS2 Technical Guidelines for Legionella Control in water system.

* The information's supplied by the customer can affect the validity of results

Test Method Variation: None

Signed for and on behalf of Testhub Laboratories LLC




 Manu P
 Laboratory Manager

Form No:TH-RF-M-002 Issue No:3 Issued On:11-09-2023

This report shall not be reproduced, unless in its entirety, without written approval from Testhub Laboratories. The results relate only to the material or product analyzed. Keywords : ND = Not Detected, NA = Not Analyzed, ppm = Parts per million, ppb = Parts per Billion, LOQ = Limit of Quantification, LOD = Limit of Detection, CFU = Colony Forming Unit, UoM=Measurement Uncertainty. Applied Decision Rule: For qualitative measurements and for zero value specifications, simple acceptance rule shall be followed by considering uncertainty U=0.For other type of specification values, binary acceptance based on guard banding formula shall be followed $U=0.5U^2-U^3$.

End of Report

Page 1 of 1

Issued To:

 Wercore Cleaning & Pest Control Services LLC
 Dubai

Report No : R1-240415-123

Report Date : 26/04/2024

Request No : Q1-240415-40

TEST REPORT

Sample Number	: S1-240415-123	Receiving Date	: 15/04/2024
Sample Description	: Domestic Water	Sampling Date/Time	: 15/04/2024; 03:45 PM
Customer Sample ID	: N/A	Sample Temperature	: 32.6°C
Project Name	: Woodlem Park school	Sample Volume Collected	: 1000ml.
Source of Sample	: Woodlem Park school, Street No.10, Al Qusais School Zone, Near Lulu hyper Market	Sampling Point	: Ground Boys Washroom
Sampled By	: EMP ID 013(TH)	Sample Receipt Temperature	: 30.1°C
Sampling Procedure	: BS 7592	Neutralizer Used	: Sodium thiosulfate
Sampling Apparatus	: Sterile Plastic Bottle	On site Observation	: Clear
Sample Container	: Sterile Plastic Bottle	Mode of Transportation	: Cool Box
Pre-Flush/Post-Flush	: Pre-Flush	Client Reference (if any)	: N/A

Test Results - Legionella

Date of Analysis: 15/04/2024 - 25/04/2024

S. No.	Test Parameters	Method	Unit	UoM (%)	Results	Specification
1	Legionella sp.,	ISO 11731: 2017	CFU/L	10.9	Not Detected	<1000

Note: Confirmatory Test for Legionella sp.,

Legionella species - Absent

Legionella pneumophila serotype 1 - Absent

Legionella pneumophila serotype 2-14 - Absent

Statement of conformity: The results of above sample are in comply with specification limit.

Specification Reference: DM-HSD-GU44-LCWS2 Technical Guidelines for Legionella Control in Water system.

Test Procedure: 7 Media Used: GVPC

Sample Volume Filtered: 250ml. and Detection limit - 4 CFU/L

Tested By: EMP ID: 006,008

Note: * The informations supplied by the customer can affect the validity of results.

Test Method Variation: None

Signed for and on behalf of Testhub Laboratories LLC


 Manu P
 Laboratory Manager

This report shall not be reproduced, unless in its entirety, without written approval from Testhub Laboratories. The results relate only to the material or product analyzed. Keywords: ND = Not Detected, NA = Not Analyzed, ppm = Parts per million, ppb = Parts per billion, LOQ = Limit of Quantification, LOD = Limit of Detection, CFU = Colony Forming Unit, UoM=Measurement Uncertainty. Applied Decision Rule: For qualitative measurements and for zero value specifications, simple acceptance rule shall be followed by considering uncertainty U=0. For other type of specification values, binary acceptance based on guard banding formula shall be followed $AL \leq U \leq U^2$.

Issued To:
Wercore Cleaning & Pest Control Services LLC
Dubai

Report No : R1-240415-124
Report Date : 18/04/2024
Request No : Q1-240415-40

TEST REPORT

Sample Number	: S1-240415-124	Receiving Date	: 15/04/2024
Sample Description	: Domestic Water	Sampling Date/Time	: 15/04/2024; 03:50 PM
Customer Sample ID	: N/A	Sample Temperature	: 34.5°C
Project Name	: Woodlem Park school	Sample Volume Collected	: 500mL
Source of Sample	: Woodlem Park school, Street No.10, Al Qusais School Zone, Near Lulu hyper Market	Sampling Point	: Ground Pantry
Sampled By	: EMP ID 013(TH)	Sample Receipt Temperature	: 32.1°C
Sampling Procedure	: APHA 9060	Neutralizer Used	: Sodium thiosulfate
Sampling Apparatus	: Sterile Plastic Bottle	On site Observation	: Clear
Sample Container	: Sterile Plastic Bottle	Mode of Transportation	: Cool Box
Pre-Flush/Post-Flush	: Post-Flush	Client Reference (if any)	: N/A

Test Results – Microbiology

Date of Analysis : 15/04/2024– 17/04/2024

S. No.	Test Parameters	Method	Unit	UoM (%)	Results	Specification
1	Total Bacterial Count	APHA 9215B	CFU/ml	6.4	<1	500 CFU/ml*

Statement of conformity: The results of above sample are in comply with specification limit.

Specification Reference: DM-HSD-GU44-LCWS2 Technical Guidelines for Legionella Control in Water system.

Tested By: EMP ID: 006,016

Note: a The GSO 149/2021 doesn't specify the limit for Aerobic Colony Count, So the specification limit was taken from DM-HSD-GU44-LCWS2 Technical Guidelines for Legionella Control in water system.

* The information's supplied by the customer can affect the validity of results

Test Method Variation: None

Signed for and on behalf of Testhub Laboratories LLC



Manu P
Manu P
Laboratory Manager

Form No:TH-RT-M-002 Issue No 3 issued On 11-04-2023

This report shall not be reproduced, unless in its entirety, without written approval from Testhub Laboratories. The results relate only to the material or product analyzed. Keywords : ND = Not Detected, NA = Not Analyzed, ppm = Parts per million, ppb = Parts per billion, LQ = Limit of Quantification, LOD = Limit of Detection, CFU = Colony Forming Unit, UoM=Measurement Uncertainty. Applied Decision Rule: For qualitative measurements and for true value specifications, simple acceptance rule shall be followed by considering uncertainty U=0 For other type of specification values, binary acceptance based on guard banding formula shall be followed $A_{max} \leq U \leq A_{min}$.

End of Report

Page 1 of 1

Issued To:
Wercore Cleaning & Pest Control Services LLC
Dubai

Report No : R1-240415-125
Report Date : 26/04/2024
Request No : Q1-240415-40

TEST REPORT

Sample Number	: S1-240415-125	Receiving Date	: 15/04/2024
Sample Description	: Domestic Water	Sampling Date/Time	: 15/04/2024; 03:50 PM
Customer Sample ID	: N/A	Sample Temperature	: 34.5°C
Project Name	: Woodlem Park school	Sample Volume Collected	: 1000mL
Source of Sample	: Woodlem Park school, Street No.10, Al Qusais School Zone, Near Lulu hyper Market	Sampling Point	: Ground Pantry
Sampled By	: EMP ID 013(TH)	Sample Receipt Temperature	: 32.1°C
Sampling Procedure	: BS 7592	Neutralizer Used	: Sodium thiosulfate
Sampling Apparatus	: Sterile Plastic Bottle	On site Observation	: Clear
Sample Container	: Sterile Plastic Bottle	Mode of Transportation	: Cool Box
Pre-Flush/Post-Flush	: Pre-Flush	Client Reference (if any)	: N/A

Test Results - Legionella

Date of Analysis: 15/04/2024 - 25/04/2024

S. No.	Test Parameters	Method	Unit	UoM (%)	Results	Specification
1	Legionella sp.,	ISO 11731: 2017	CFU/L	10.9	Not Detected	<1000

Note: Confirmatory Test for Legionella sp.,
Legionella species - Absent
Legionella pneumophila serotype 1 - Absent
Legionella pneumophila serotype 2-14 - Absent

Statement of conformity: The results of above sample are in comply with specification limit.

Specification Reference: DM-HSD-GU44-LCWS2 Technical Guidelines for Legionella Control in Water system.

Test Procedure: 7 Media Used: GVPC

Sample Volume Filtered: 250mL and Detection limit - 4 CFU/L

Tested By: EMP ID: 006,008

Note: * The informations supplied by the customer can affect the validity of results.

Test Method Variation: None

Signed for and on behalf of Testhub Laboratories LLC




Manu P
Laboratory Manager

This report shall not be reproduced, unless in its entirety, without written approval from Testhub Laboratories. The results relate only to the material or product analyzed. Keywords : ND = Not Detected, NA = Not Analyzed, ppm = Parts per million, ppb = Parts per billion, LOQ = Limit of Quantification, LOD = Limit of Detection, CFU = Colony Forming Unit, UoM=Measurement Uncertainty. Applied Decision Rule: For qualitative measurements and for zero value specifications, single acceptance rule shall be followed by considering uncertainty U=0. For other type of specifications values, binary acceptance based on guard banding formula shall be followed $U=0.5 \cdot U^*$.

Issued To:
Wercore Cleaning & Pest Control Services LLC
Dubai

Report No : R1-240415-126
Report Date : 18/04/2024
Request No : Q1-240415-40

TEST REPORT

Sample Number	: S1-240415-126	Receiving Date	: 15/04/2024
Sample Description	: Domestic Water	Sampling Date/Time	: 15/04/2024; 03:55 PM
Customer Sample ID	: N/A	Sample Temperature	: 34.9°C
Project Name	: Woodlem Park school	Sample Volume Collected	: 500mL
Source of Sample	: Woodlem Park school, Street No.10, Al Qusais School Zone, Near Lulu hyper Market	Sampling Point	: Outside Water Tap Near To Reception
Sampled By	: EMP ID 013(TH)	Sample Receipt Temperature	: 32.1°C
Sampling Procedure	: APHA 9060	Neutralizer Used	: Sodium thiosulfate
Sampling Apparatus	: Sterile Plastic Bottle	On site Observation	: Clear
Sample Container	: Sterile Plastic Bottle	Mode of Transportation	: Cool Box
Pre-Flush/Post-Flush	: Post-Flush	Client Reference (if any)	: N/A

Test Results – Microbiology

Date of Analysis : 15/04/2024– 17/04/2024

S. No.	Test Parameters	Method	Unit	UoM (%)	Results	Specification
1	Total Bacterial Count	APHA 9215B	CFU/ml	6.4	<1	500 CFU/ml*

Statement of conformity: The results of above sample are in comply with specification limit.

Specification Reference: DM-HSD-GU44-LCWS2 Technical Guidelines for Legionella Control in Water system.

Tested By: EMP ID: 006,016

Note: a The GSO 149/2021 doesn't specify the limit for Aerobic Colony Count, So the specification limit was taken from DM-HSD-GU44-LCWS2 Technical Guidelines for Legionella Control in water system.

* The information's supplied by the customer can affect the validity of results

Test Method Variation: None

Signed for and on behalf of Testhub Laboratories LLC




Manu P
Laboratory Manager

Form No:TH-IF-M-002 Issue No 3 Issued On 11-09-2023

This report shall not be reproduced, unless in its entirety, without written approval from Testhub Laboratories. The results relate only to the material or product analyzed. Keywords: ND = Not Detected, NA = Not Analyzed, ppm = Parts per million, ppb = Parts per Billion, LOQ = Limit of Quantification, LOD = Limit of Detection, CFU = Colony Forming Unit, UoM=Measurement Uncertainty. Applied Decision Rule: For qualitative measurements and for zero value specifications, single acceptance rule shall be followed by considering uncertainty U=0. For other type of specification values, binary acceptance based on guard banding formula shall be followed $A \leq U \leq A+U$.

End of Report

Page 1 of 1

Issued To:
 Wercore Cleaning & Pest Control Services LLC
 Dubai

Report No : RI-240415-127
 Report Date : 26/04/2024
 Request No : QI-240415-10

TEST REPORT

Sample Number	: S1-240415-127	Receiving Date	: 15/04/2024
Sample Description	: Domestic Water	Sampling Date/Time	: 15/04/2024; 03:55 PM
Customer Sample ID	: N/A	Sample Temperature	: 34.9°C
Project Name	: Woodlem Park school	Sample Volume Collected	: 1000mL
Source of Sample	: Woodlem Park school, Street No.10, Al Qusais School Zone, Near Lulu hyper Market	Sampling Point	: Outside Water Tap Near To Reception
Sampled By	: EMP ID 013(TII)	Sample Receipt Temperature	: 32.1°C
Sampling Procedure	: BS 7592	Neutralizer Used	: Sodium thiosulfate
Sampling Apparatus	: Sterile Plastic Bottle	On site Observation	: Clear
Sample Container	: Sterile Plastic Bottle	Mode of Transportation	: Cool Box
Pre-Flush/Post-Flush	: Pre-Flush	Client Reference (if any)	: N/A

Test Results - Legionella

Date of Analysis: 15/04/2024 - 25/04/2024

S. No.	Test Parameters	Method	Unit	UoM (%)	Results	Specification
1	Legionella sp.,	ISO 11731: 2017	CFU/L	10.9	Not Detected	<1000

Note: Confirmatory Test for Legionella sp.,
 Legionella species - Absent
 Legionella pneumophila serotype 1 - Absent
 Legionella pneumophila serotype 2-14 - Absent

Statement of conformity: The results of above sample are in comply with specification limit.

Specification Reference: DM-HSD-GU44-LCWS2 Technical Guidelines for Legionella Control in Water system.

Test Procedure: 7 Media Used: GVPC

Sample Volume Filtered: 250mL and Detection limit - 4 CFU/L

Tested By: EMP ID: 006,008

Note: * The informations supplied by the customer can affect the validity of results.

Test Method Variation: None

Signed for and on behalf of Testhub Laboratories LLC




 Manu P
 Laboratory Manager

This report shall not be reproduced, unless in its entirety, without written approval from Testhub Laboratories. The results relate only to the material or product analyzed. Keywords : ND = Not Detected, NA = Not Analyzed, ppm = Parts per million, ppb = Parts per billion, LOQ = Limit of Quantification, LOD = Limit of Detection, CFU = Colony Forming Unit, UoM=Measurement Uncertainty. Applied Decision Rule: For qualitative measurements and for zero value specifications, simple acceptance rule shall be followed by considering uncertainty U=0. For other type of specification values, binary acceptance based on guard banding formula shall be followed $A_{acc} = U \cdot U^1$.

Issued To:
Wercore Cleaning & Pest Control Services LLC
Dubai

Report No : R1-240415-128
Report Date : 18/04/2024
Request No : Q1-240415-40

TEST REPORT

Sample Number	: S1-240415-128	Receiving Date	: 15/04/2024
Sample Description	: Domestic Water	Sampling Date/Time	: 15/04/2024; 04:00 PM
Customer Sample ID	: N/A	Sample Temperature	: 34.0°C
Project Name	: Woodlem Park school	Sample Volume Collected	: 500mL
Source of Sample	: Woodlem Park school, Street No.10, Al Qusais School Zone, Near Lulu hyper Market	Sampling Point	: Ground Girls Washroom
Sampled By	: EMP ID 013(TH)	Sample Receipt Temperature	: 32.4°C
Sampling Procedure	: APHA 9060	Neutralizer Used	: Sodium thiosulfate
Sampling Apparatus	: Sterile Plastic Bottle	On site Observation	: Clear
Sample Container	: Sterile Plastic Bottle	Mode of Transportation	: Cool Box
Pre-Flush/Post-Flush	: Post-Flush	Client Reference (if any)	: N/A

Test Results - Microbiology

Date of Analysis: 15/04/2024- 17/04/2024

S. No.	Test Parameters	Method	Unit	UoM (%)	Results	Specification
1	Total Bacterial Count	APHA 9215B	CFU/ml	6.4	<1	500 CFU/ml ^a

Statement of conformity: The results of above sample are in comply with specification limit.

Specification Reference: DM-HSD-GU44-LCWS2 Technical Guidelines for Legionella Control in Water system.

Tested By: EMP ID: 006,016


Note: a The GSO 149/2021 doesn't specify the limit for Aerobic Colony Count, So the specification limit was taken from DM-HSD-GU44-LCWS2 Technical Guidelines for Legionella Control in water system.

* The information's supplied by the customer can affect the validity of results

Test Method Variation: None

Signed for and on behalf of Testhub Laboratories LLC




Manu P
Laboratory Manager

Form No:THS-RF-M-002 Issue No 3 Issued On 11-09-2023

This report shall not be reproduced, unless in its entirety, without written approval from Testhub Laboratories. The results relate only to the material or product analyzed. Keywords: ND = Not Detected, NA = Not Analyzed, ppm = Parts per million, ppb = Parts per billion, LOQ = Limit of Quantification, LOD = Limit of Detection, CFU = Colony Forming Unit, UoM=Measurement Uncertainty. Applied Decision Rule: For qualitative measurements and for zero value specifications, simple acceptance rule shall be followed by considering uncertainty $U=0$. For other type of specification values, binary acceptance based on guard banding formula shall be followed $A=U/1.64$.

End of Report

Page 1 of 1

Issued To:
 Wercore Cleaning & Pest Control Services LLC
 Dubai

Report No : R1-240415-129
 Report Date : 26/04/2024
 Request No : Q1-240415-40

TEST REPORT

Sample Number	: S1-240415-129	Receiving Date	: 15/04/2024
Sample Description	: Domestic Water	Sampling Date/Time	: 15/04/2024; 04:00 PM
Customer Sample ID	: N/A	Sample Temperature	: 34.0°C
Project Name	: Woodlem Park school	Sample Volume Collected	: 1000mL
Source of Sample	: Woodlem Park school, Street No.10, Al Qusais School Zone, Near Lulu hyper Market	Sampling Point	: Ground Girls Washroom
Sampled By	: EMP ID 013(TH)	Sample Receipt Temperature	: 32.4°C
Sampling Procedure	: BS 7592	Neutralizer Used	: Sodium thiosulfate
Sampling Apparatus	: Sterile Plastic Bottle	On site Observation	: Clear
Sample Container	: Sterile Plastic Bottle	Mode of Transportation	: Cool Box
Pre-Flush/Post-Flush	: Pre-Flush	Client Reference (if any)	: N/A

Test Results - Legionella

Date of Analysis: 15/04/2024 - 25/04/2024

S. No.	Test Parameters	Method	Unit	UoM (%)	Results	Specification
1	Legionella sp.,	ISO 11731: 2017	CFU/L	10.9	Not Detected	<1000

Note: Confirmatory Test for Legionella sp.,
 Legionella species - Absent
 Legionella pneumophila serotype 1 - Absent
 Legionella pneumophila serotype 2-14 - Absent

Statement of conformity: The results of above sample are in comply with specification limit.

Specification Reference: DM-HSD-GU44-LCWS2 Technical Guidelines for Legionella Control in Water system.

Test Procedure: 7 Media Used: GVPC

Sample Volume Filtered: 250mL and Detection limit - 4 CFU/L

Tested By: EMP ID: 006,008

Note: * The informations supplied by the customer can affect the validity of results.

Test Method Variation: None



Signed for and on behalf of Testhub Laboratories LLC


 Manu P
 Laboratory Manager

This report shall not be reproduced, unless in its entirety, without written approval from Testhub Laboratories. The results relate only to the material or product analyzed. Keywords: ND = Not Detected, NA = Not Analyzed, ppm = Parts per million, ppb = Parts per billion, LOQ = Limit of Quantification, LOD = Limit of Detection, CFU = Colony Forming Unit, UoM=Measurement Uncertainty. Applied Decision Rule: For qualitative measurements and for zero value specifications, simple acceptance rule shall be followed by considering uncertainty U=0. For other type of specification values, binary acceptance based on guard banding formula shall be followed $U=U_{L}/2$.